

SWPPP

1. Please include a table of contents in the document.
2. Please note a 5-acre waiver will need to be obtained from the Department to disturb more than 5 acres of soil at one time. The final SWPPP will need to be submitted to the Department for review and approval for a waiver.
3. Appendix C1-1 contains the stormwater general permit GP-0-15-002. However, this permit expired January 28 and coverage will be under the current general permit GP-0-20-001. Please replace the permit in the appendix with the current permit.
4. While the SWPPP provides calculations for the WQv and RRv, it does not establish that proposed SMPs will adequately treat the calculated WQv. Please include calculations that show the proposed SMPs are sized to sufficiently treat the water quality volume.

Drawings

1. Please make sure the final plans are signed and stamped by a licensed New York State P.E.
2. Please include a grading plan and a map of post construction stormwater practices.
3. Please include detail for the level spreaders in Sheet ES1.03, Erosion and Sedimentation Control Details.